



Contents

Summary of general arrangements 3

Assembly Point..... 4

Ground floor..... 5

Floor 1 6

Floor 2 7

Summary of general arrangements


| | |
|---|--|
| Alarm tests: | <ul style="list-style-type: none">• The fire alarm audibility test is undertaken on Thursdays.• The test will last for no more than 15 seconds.• If an alarm sounds for more than 15 seconds or on any other day, you must evacuate. |
| Refuge Points | <ul style="list-style-type: none">• The four stairwells are all protected stairs, and the landings can be used as a temporary refuge that is safe from smoke and flame ingress for at least 30 minutes when the fire doors are closed.• Communication with the evacuation management team can be made by phoning the University's Security Emergency number on 0113 812 4444. |
| Final exits with level access | <ul style="list-style-type: none">• The main entrance (pictured on the cover) and the exit closest to Fairfax Hall have level access egress.• All other exit routes have short flights of external steps. |
| Lifts  | <ul style="list-style-type: none">• The lift cannot be used in the event of the fire alarm being activated.• An evacuation chair can be requested from Security by calling 0113 812 4444. |

Assembly Point




Assembly point

Ground floor




-  Level access Fire Exit
-  Alternative exit but with some external steps
-  Protected Stairwell

Floor 1



Protected Stairwell

Floor 2



 Protected Stairwell